



APPROVED

Certificate of Compliance

Steel Pipe for Automatic Fire Protection Systems

This certificate is issued for the following equipment:

Model Types: Steel Pipe Schedules: 10, 30, 40, 80 and Lightwall
Sizes 1 Through 10 inch NPS
(Sizes shown in detail on attached pages)

Manufactured by:
Borusan Mannesmann Boru
Hisar Mahallesi Gem saz Mevkii
16601 Gemlik - Bursa
Turkey

FM Approvals confirms that the items have been found to comply with the following standard:

FM Approvals Standard 1630 (November 2004)


Project Identifier: 3025409 Date of Approval: May 05, 2008

Richard B. Dunne
Group Manager - Hydraulics

Date May 5, 2008



Member of the FM Global Group



APPROVED

Certificate of Compliance

Pipe Designation	Nominal Pipe Sizes	Rated Working Pressure, psi (kPa)
Schedule 10	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8	300 (2070)
Schedule 30	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10	300 (2070)
Schedule 40	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10	300 (2070)
Schedule 80	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10	300 (2070)
"Easy Flow"	1-1/4, 1-1/2, 2, 2-1/2, 3, 4	300 (2070)



Member of the FM Global Group